

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 2

V. RECEIVING WATERS:

The discharge is into a drainage ditch; thence into English Bayou; thence into the Calcasieu River in segment 030702 of the Calcasieu River Basin. This segment is not listed on the 303(d) list of impaired waterbodies.

The designated uses and degree of support for Segment 030702 of the Calcasieu River Basin are as indicated in the table below^{1/}:

Overall Degree of Support for Segment 030702	Degree of Support of Each Use						
	Primary Contact Recreation	Secondary Contact Recreation	Propagation of Fish & Wildlife	Outstanding Natural Resource Water	Drinking Water Supply	Shell fish Propagation	Agriculture
Partial	Full	Full	Not Supported	N/A	N/A	N/A	Full

^{1/}The designated uses and degree of support for Segment 030702 of the Calcasieu River Basin are as indicated in LAC 33:IX.1123.C.3, Table (3) and the 2006 Water Quality Management Plan, Water Quality Inventory Integrated Report, Appendix A, respectively.

VI. ENDANGERED SPECIES:

The receiving waterbody, Subsegment 030702 of the Calcasieu River Basin, is not listed in Section II.2 of the Implementation Strategy as requiring consultation with the U. S. Fish and Wildlife Service (FWS). This strategy was submitted with a letter dated November 17, 2008 from Rieck (FWS) to Nolan (LDEQ). Therefore, in accordance with the Memorandum of Understanding between the LDEQ and the FWS, no further informal (Section 7, Endangered Species Act) consultation is required. It was determined that the issuance of the LPDES permit is not likely to have an adverse effect on any endangered or candidate species or the critical habitat. The effluent limitations established in the permit ensure protection of aquatic life and maintenance of the receiving water as aquatic habitat.

VII. HISTORIC SITES:

The discharge is from an existing facility location, which does not include an expansion beyond the existing perimeter. Therefore, there should be no potential effect to sites or properties on or eligible for listing on the National Register of Historic Places, and in accordance with the 'Memorandum of Understanding for the Protection of Historic Properties in Louisiana Regarding LPDES Permits' no consultation with the Louisiana State Historic Preservation Officer is required.

VIII. PUBLIC NOTICE:

Upon publication of the public notice, a public comment period shall begin on the date of publication and last for at least 30 days thereafter. During this period, any interested persons may submit written comments on the draft permit and may request a public hearing to clarify issues involved in the permit decision at this Office's address on the first page of the statement of basis. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 3

Public notice published in:

Local newspaper of general circulation

Office of Environmental Services Public Notice Mailing List

For additional information, contact:

Ms. Afton J. Bessix
Water Permits Division
Department of Environmental Quality
Office of Environmental Services
P. O. Box 4313
Baton Rouge, Louisiana 70821-4313

IX. PROPOSED PERMIT LIMITS:

Subsegment 030702, English Bayou – Headwaters to Calcasieu River, is listed on LDEQ's Final 2006 303(d) list as impaired for mercury and total dissolved solids. Although TMDL's for the Calcasieu River Basin were due to be completed by 2001, a TMDL has not yet been developed for mercury and TDS for this waterbody. A TMDL will be scheduled following completion of the EPA Consent Decree TMDL schedule. A reopener clause will be established in the permit to allow for the requirement of more stringent effluent limitations and requirements as imposed by a future TMDL.

Total Dissolved Solids (TDS)

Based on the size and nature of the facility, the Department believes there is little potential for the discharge to cause or contribute to the TDS impairment of this segment. Therefore, no limitation for TDS will be required of this facility at this time.

Organic Enrichment/Low DO and Nutrients have been delisted as impairments due to data from TMDLs previously received from LDEQ and approved by the EPA.

Mercury has been delisted as an impairment since there is no fish advisory for this subsegment. A review of historical WQ data shows that this waterbody is currently meeting water quality standards for water column Hg.

Subsegment 030702 was previously listed as impaired for suspended solids/turbidity on past 303(d) lists, for which the below TMDL's have been developed. The Department of Environmental Quality reserves the right to impose more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon additional TMDL's and/or water quality studies. The DEQ also reserves the right to modify or revoke and reissue this permit based upon any changes to established TMDL's for this discharge, or to accommodate for pollutant trading provisions in approved TMDL watersheds as necessary to achieve compliance with water quality standards.

The following TMDL's have been established for subsegment 030702:

TMDL for Suspended Solids and Turbidity for English Bayou in the Calcasieu River Basin

As per the TMDL, point sources do not represent a source of TSS as defined in this TMDL. Wastewater treatment facilities discharge primarily organic TSS, which does not contribute to extensive habitat impairment resulting from sedimentation. Municipal permits contain a TSS limitation and a specific narrative requirement to prevent organic solids accumulation. Because an enforceable mechanism is in place to protect from discharges of organic suspended solids no TMDL is required for these materials.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 4

Final Effluent Limits:**OUTFALL 001**

Final limits shall become effective on the effective date of the permit and expire on the expiration date of the permit.

Effluent Characteristic	Monthly Avg (lbs./day)	Monthly Avg	Weekly Avg	Basis
CBOD ₅	42	10 mg/l	15 mg/l	Limits are set in accordance with Water Quality Based Limits Amended Advanced Treatment Review (ATR) for Calcasieu Sewer District #11 (ATR 89.16).
TSS	63	15 mg/l	23 mg/l	Since there is no numeric water quality criterion for TSS, and in accordance with the current Water Quality Management Plan, the TSS effluent limitations shall be based on a case-by-case evaluation of the treatment technology being utilized at a facility. Therefore, a Technology Based Limit has been established through Best Professional Judgement for the type of treatment technology utilized at this facility.
Ammonia-Nitrogen	21	5 mg/l	10 mg/l	Limits are set in accordance with Water Quality Based Limits Amended Advanced Treatment Review (ATR) for Calcasieu Sewer District #11 (ATR 89.16).

*Concentration limits are used in accordance with LAC 33:IX.2709.F.1.b which states that mass limitations are not necessary when applicable standards and limitations are expressed in other units of measurement. LAC 33:IX.709.B references LAC 33:IX.711 which express BOD₅ and TSS in terms of concentration.

Other Effluent Limitations:**1) Fecal Coliform**

The discharge from this facility is into a water body which has a designated use of Primary Contact Recreation. According to LAC 33:IX.1113.C.5., the fecal coliform standards for this water body are 200/100 ml and 400/100 ml. Therefore, the limits of 200/100 ml (Monthly Average) and 400/100 ml (Weekly Average) are proposed as Fecal Coliform limits in the permit. These limits are being proposed through Best Professional Judgement in order to ensure that the water body standards are not exceeded, and due to the fact that existing facilities have demonstrated an ability to comply with these limitations using present available technology.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 5

2) pH

According to LAC 33:IX.3705.A.1., POTW's must treat to at least secondary levels. Therefore, in accordance with LAC 33:IX.5905.C., the pH shall not be less than 6.0 standard units nor greater than 9.0 standard units at any time.

3) Solids and Foam

There shall be no discharge of floating solids or visible foam in other than trace amounts in accordance with LAC 33:IX.1113.B.7.

X. PREVIOUS PERMITS:

LPDES Permit No. LA0043605: Issued: September 1, 2004
Expired: August 31, 2009

<u>Effluent Characteristic</u>	<u>Discharge Limitations</u>		<u>Monitoring Requirements</u>	
	<u>Monthly Avg.</u>	<u>Weekly Avg.</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	Report	Report	Continuous	Recorder
CBOD ₅	10 mg/l	15 mg/l	2/month	Grab
TSS	15 mg/l	23 mg/l	2/month	Grab
Ammonia-Nitrogen	5 mg/l	10 mg/l	2/month	Grab
Fecal Coliform Colonies	200	400	2/month	Grab
pH (standard units)	6.0 s.u.	9.0 s.u.	2/month	Grab

The permit contains pollution prevention language.

XI. ENFORCEMENT AND SURVEILLANCE ACTIONS:

A) Inspections

A review of the files indicates the following inspections were performed during the period beginning March 2007 and ending February 2009 for this facility.

Date: November 16, 2007

Inspector: LDEQ

Findings and/or Violations:

1. Reviewed records and DMR's from December 2003 to current and discovered eight excursions and four over flows.
2. Filters in the aeration chamber are removed and cleaned every three months.
3. Facility appears to be well maintained and good house keeping practices were noted.
4. The second cell of the oxidation pond did have a lot of duckweed and a few weeds growing within the baffle system.
5. The flow meter had been replaced since the last CEI and appeared to be functioning properly.
6. Work was done to the baffle system after the last CEI, but some damage did occur during Hurricane Rita.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 6

A Hurricane Rita related inspection was also conducted at this facility.

Date: September 17, 2008

Inspector: LDEQ

Findings and/or Violations:

1. Facility is running normally.
2. No impact from Hurricane Ike.
3. Facility has baffles stacked up ready to replace from Hurricane Rita.

B) Compliance and/or Administrative Orders

A review of the files indicates that no recent enforcement actions have been administered against this facility. However, a Notice of Deficiency was sent to the permittee dated January 8, 2008 referencing areas of concern noted in the inspection report and/or subsequent file review. As of February 15, 2008, LDEQ determined that the areas of concern identified have been adequately addressed.

C) DMR Review

A review of the discharge monitoring reports for the period beginning March 2007 through February 2009 has revealed the following violations:

Parameter	Outfall	Period of Excursion	Permit Limit	Reported Quantity
Fecal Coliform	Outfall 001	May 2007	400/100 mL	460/100 mL
Ammonia	Outfall 001	June 2007	21 lbs/day 5 mg/L 10 mg/L	22.1 lbs/day 9.5 mg/L 12.0 mg/L
Ammonia	Outfall 001	July 2007	21 lbs/day 5 mg/L 10 mg/L	64.4 lbs/day 9.7 mg/L 12.7 mg/L
Fecal Coliform	Outfall 001	July 2007	400/100 mL	>1,000/100 mL
Ammonia	Outfall 001	August 2007	21 lbs/day 5 mg/L	29.2 lbs/day 5.8 mg/L
Ammonia	Outfall 001	April 2008	21 lbs/day	21.9 lbs/day
CBOD ₅	Outfall 001	June 2008	15 mg/L	24 mg/L
Ammonia	Outfall 001	August 2008	21 lbs/day	33.5 lbs/day
TSS	Outfall 001	December 2008	15 mg/L 23 mg/L	17 mg/L 28 mg/L
Ammonia	Outfall 001	January 2009	21 lbs/day	21.2 lbs/day
Ammonia	Outfall 001	February 2009	5 mg/L	6.1 mg/L

XII. ADDITIONAL INFORMATION:

The Louisiana Department of Environmental Quality (LDEQ) reserves the right to impose more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon additional water quality studies and/or TMDL's. The LDEQ also reserves the right to modify or revoke and reissue this permit based upon any changes to established TMDL's for this discharge, or to accommodate for pollutant trading provisions in approved TMDL watersheds as requested by the permittee and/or as necessary to achieve compliance with water quality standards. Therefore, prior to upgrading or expanding this facility, the permittee should contact the Department to determine the status of the work being done to establish future effluent limitations and additional permit conditions.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 7

In accordance with LAC 33:IX.2903., this permit may be modified, or alternatively, revoked and reissued, to comply with any applicable effluent standard or limitations issued or approved under sections 301(b)(2)(c) and (D); 304(b)(2); and 307(a)(2) of the Clean Water Act, if the effluent standard or limitations so issued or approved:

- a) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- b) Controls any pollutant not limited in the permit; or
- c) Requires reassessment due to change in 303(d) status of waterbody; or
- d) Incorporates the results of any total maximum daily load allocation, which may be approved for the receiving water body.

Final effluent loadings (i.e. lbs/day) have been established based upon the permit limit concentrations and the design capacity of 0.50 MGD.

Effluent loadings are calculated using the following example:

$$\text{BOD: } 8.34 \text{ lb/gal} \times 0.50 \text{ MGD} \times 10 \text{ mg/l} = 42 \text{ lb/day}$$

At present, the **Monitoring Requirements, Sample Types, and Frequency of Sampling** as shown in the permit are standard for facilities of flows between 0.1 MGD and 0.5 MGD.

Effluent CharacteristicsMonitoring Requirements

	<u>Measurement</u>	<u>Sample</u>
	<u>Frequency</u>	<u>Type</u>
Flow	Continuous	Recorder
CBOD ₅	1/week	Grab
Total Suspended Solids	1/week	Grab
Ammonia-Nitrogen	1/week	Grab
Fecal Coliform Bacteria	1/week	Grab
pH	1/week	Grab

Pretreatment Requirements

Based upon consultation with LDEQ pretreatment personnel, general pretreatment language will be used due to the lack of either an approved or required pretreatment program.

Pollution Prevention Requirements

The permittee shall institute or continue programs directed towards pollution prevention. The permittee shall institute or continue programs to improve the operating efficiency and extend the useful life of the facility. The permittee will complete an annual Environmental Audit Report **each year** for the life of this permit according to the schedule below. The permittee will accomplish this requirement by completing an Environmental Audit Form which has been attached to the permit. All other requirements of the Municipal Wastewater Pollution Prevention Program are contained in Part II of the permit.

Statement of Basis

LA0043605; AI 41915; PER20090001

Page 8

The audit evaluation period is as follows:

Audit Period Begins	Audit Period Ends	Audit Report Completion Date
Effective Date of Permit	12 Months from Audit Period Beginning Date	3 Months from Audit Period Ending Date

XIII. TENTATIVE DETERMINATION:

On the basis of preliminary staff review, the Department of Environmental Quality has made a tentative determination to reissue a permit for the discharge described in this Statement of Basis.

XIV. REFERENCES:

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 8, "Wasteload Allocations / Total Maximum Daily Loads and Effluent Limitations Policy," Louisiana Department of Environmental Quality, 2005.

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 5, "Water Quality Inventory Section 305(b) Report," Louisiana Department of Environmental Quality, 1998.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Chapter 11 - "Louisiana Surface Water Quality Standards," Louisiana Department of Environmental Quality, 2004.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Subpart 2 - "The LPDES Program," Louisiana Department of Environmental Quality, 2004.

Low-Flow Characteristics of Louisiana Streams, Water Resources Technical Report No. 22, United States Department of the Interior, Geological Survey, 1980.

Index to Surface Water Data in Louisiana, Water Resources Basic Records Report No. 17, United States Department of the Interior, Geological Survey, 1989.

LPDES Permit Application to Discharge Wastewater, Town of Iowa, Town of Iowa SD #1, March 8, 2009.